



NOTE:

1. SWALE ELEVATION SHALL BE 6" MIN. BELOW THE LOWEST ADJACENT ELEVATION.
2. BIOSWALES SHALL NOT BE CONSTRUCTED UNTIL ALL CONTRIBUTING DRAINAGE AREAS HAVE BEEN STABILIZED.
3. COORDINATE PERFORATED PIPE UNDER DRAINAGE SYSTEMS WITH CIVIL DRAWINGS.

FAST DRAINING BIOSWALE SOLID MIX TO INCLUDE

- 50% COUSE SAND
- 20% PEAT MOSS
- 30% SANDY LOAM

SECTION

Additional cover may be required based on site conditions. 12" cover required to obtain an H-10 Load rating. Consult with a local Engineer for site specific requirements.



EZ-FLOW

AGGREGATE DRAINAGE SYSTEM

TECHNICAL SERVICES
1-888-825-4716
techservice@ndspro.com

N. T. S.